

From: Kaden Mollett

Sent: Thursday, March 19, 2026 9:25 AM

Subject: Project #26-10 Addendum #3

To keep all information consistent,

I am providing clarification on the following question asked on 03/18/2026 at 11:58 AM, for the IFB (#26-10) that was issued on 02/20/2026 at 1:30 PM.

Question 1: **What is the required thickness of the blacktop parking lot?**

Answer: **The asphalt paving shall match the thickness of the existing asphalt, which is approximately 4 inches.**

Question 2: **How thick does the pad for the roll-off dumpster need to be?**

Answer: **The roll-off dumpster pad shall be 10 inches thick and reinforced with wire mesh to provide adequate support.**

Question 3: **Is the pad for the roll-off dumpster set at the same elevation as the new shop floor?**

Answer: **No, the dumpster pad shall be constructed to match the elevation of the surrounding blacktop or concrete surfaces (e.g., sidewalk or curb height), not the elevation of the new shop floor.**

Kind Regards,

Kaden Mollet

Procurement Specialist,
Marion County Housing Authority

719 Howard St
Centralia, IL 62801
618.532.1894 ext 310
www.mchahomes.org