



Addendum No. 2 – RFQ #26-77 – Laundry Room Exhaust Fan Installation

Issued: October 14, 2026

This Addendum provides clarifications to the Request for Quotes (RFQ) based on questions received and discussions held during the pre-quote conference and site walkthrough. The information contained herein shall be incorporated into the RFQ documents and shall supersede any conflicting requirements previously stated.

Questions & Answers

Question 1: Is there existing attic access?

Answer 1: Yes. The building has existing attic access that allows entry into the attic space.

Question 2: Is the Marion County Housing Authority tax exempt?

Answer 2: Yes. The Marion County Housing Authority (MCHA) is a tax-exempt entity.

Clarifications

1. Exhaust Fan Discharge Routing Clarification

During the pre-quote site walkthrough, it was determined that routing the exhaust fan discharge through the roof is the preferred installation method. While the RFQ indicates that either a wall or roof exit is acceptable, a detailed site review found that a wall penetration would be difficult due to existing utilities, equipment, and other obstructions located on and within the wall.

Therefore, bidders shall base their quotations on a roof exit installation. The quoted price shall include all labor, materials, roof penetrations, flashing, sealing, weatherproofing, and associated work required to provide a complete and operational installation.

All work shall be performed in accordance with applicable federal, state, and local code regulations.

Acknowledgment

Please ensure that Addendum No. 2 is acknowledged on your submitted quote for RFQ #26-77.

End of Addendum No. 2